

August 2024



**Pull Out Test Data: 38.2SSLPW Colour Coded Fixings**

- Equipment:
  - Hydrajaws 0095C
  - Digital Dial POG-2ED
  - Calibrated 02.10.23

Test No.	Application	Result (Failure Load)	Average Result per Application
1	3 x 2mm Aluminium Sheet into 18mm Plywood	2.9kN	3.1kN
2	3 x 2mm Aluminium Sheet into 18mm Plywood	3.2kN	
3	3 x 2mm Aluminium Sheet into 18mm Plywood	3.1kN	
4	2 x 2mm Aluminium Sheet into 18mm Plywood	2.7kN	2.6kN
5	2 x 2mm Aluminium Sheet into 18mm Plywood	2.5kN	
6	2 x 2mm Aluminium Sheet into 18mm Plywood	2.5kN	
7	1 x 2mm Aluminium Sheet into 18mm Plywood	1.8kN	1.8kN
8	1 x 2mm Aluminium Sheet into 18mm Plywood	2.0kN	
9	1 x 2mm Aluminium Sheet into 18mm Plywood	1.6kN	
10	2 x 2mm Aluminium Sheet Only	2.5kN	2.4kN
11	2 x 2mm Aluminium Sheet Only	2.3kN	
12	2 x 2mm Aluminium Sheet Only	2.4kN	